



# Grid Reliability Services by Variable Renewable Generation

Vahan Gevorgian, NREL



Workshop on "99+ Grid Availability for RE Integration"  
January 23, 2018  
Chennai, India

# How are US System operators integrating and balancing renewables?


- Energy market designed around reliability and affordability
- Both day-ahead and real-time energy and ancillary services markets
- New gas units designed with high levels of flexibility
  - “Must offer” market obligation – generator to bid portion of their most flexible capacity, so it is always available
  - Flexible ramping products
- Improved forecasting
- Energy imbalance markets
- Distribution system planning and innovation
- Interconnection standards and cost allocation for distributed generation and storage
- Subhourly dispatch co-optimized with reliability (N-1)
- Adoption of new technologies (energy storage)
- Renewables helping to integrate more renewables (advanced grid-friendly controls by wind and solar)

# NERC Essential Reliability Services

- Services based Active Power Control
  - Inertial response
  - Primary frequency response
  - Secondary frequency response (AGC)
  - Ramp control
  - Economic dispatch following
- Services based on Reactive Power Control
  - Voltage, power factor and VAR control (night-time VAR control)
- Performance during and after disturbances
  - LVRT/ZVRT/HVRT
  - Short circuit current contribution
  - Frequency disturbance ride-through



# Standard BAL-003-01 Frequency Response Metrics Explained




- Initial rate of decline of frequency (ROCOF)
- Value of frequency nadir (point C)
- A-to-C transition time
- Value of settling frequency (point B)
- C-to-B transition time
- C/B ratio

## Interconnection Frequency Response Obligation (IFRO)

- Calculated using statistical observations from many similar events
- Depends on
  - Initial frequency
  - First step of UFLS
  - Contingency criteria
  - Governor withdrawal adjustment
  - C/B ratio
  - Demand response credit
- **WI FRO = -906 MW/0.1 Hz**
- **BAL-003-1 standard also sets FRO for all BA within interconnections**


# Historic Western Interconnection Frequency Response



Source: NERC M-4 Interconnection Frequency Response database ([www.nerc.com](http://www.nerc.com))

- Slow decreasing trend in W.I. frequency response
- Can be caused by several factors, not necessarily by increasing penetration of wind and solar PV generation
- Cause of some concern, but the W.I. frequency response is not in crisis by no means

# Frequency Droop Control By Wind Power Generation




- Plant level control
- Continuous curtailed operation is needed to maintain headroom for up regulation
- Easy for wind to provide non-symmetric droop characteristic

# 80% Wind Penetration Study

## WWSIS-1 In-Area Scenarios

Area	Wind Rating (MW), 10% Case	Wind Rating (MW), 20% Case	Wind Rating (MW), 30% Case
Arizona	3,600	7,350	11,220
Colorado–East	2,040	3,780	5,640
Colorado–West	300	600	900
New Mexico	1,080	1,920	2,790
Nevada	2,340	4,680	7,050
Wyoming	930	1,620	2,340
COB*	90	90	180
Idaho–East	660	660	780
Idaho–SW	750	750	1,500
Montana	780	780	1,050
N. California	5,610	5,610	11,790
Northwest	6,540	6,540	12,930
S. California	7,110	7,110	14,490
Utah	1,410	1,410	2,730
<b>Total</b>	<b>33,240</b>	<b>42,900</b>	<b>75,390</b>



## Wind Nameplate Capacities


Penetration	Total Wind Nameplate Capacity (GW)	Wind Generation Level (GW)
15% base case	23	17.92
20%	41.65	22.5
30%	60.34	33.76
40%	80.45	45.19
50%	101.67	56.89
80%	180.49	85.51

TEPCC 2022 light spring load base case

## Simulations Performed


Case	Wind Controls Scenarios			
15%				
20%				
30%	No inertia, no PFR	Inertia only	PFR only (5% headroom; 5% droop)	Inertia + PFR (5% headroom; 5% droop)
40%				
50%				
80%				

# 15% base case







# 20% case




# 30% case




# 40% case




# 50% case



# 80% case




# Impact of Wind Controls of Frequency Nadir




- Combining Inertial and primary frequency controls by wind results in nadir improvement with increasing penetration

# Impact of Wind Controls on Settling Frequency



- Combining Inertial and primary frequency controls by wind power results in continuous settling frequency improvement

# Impacts on Individual Technologies: combined cycle





# 2015 Demonstration Projects in Puerto Rico and Texas



- 20 MW AES Ilumina PV plant
- Location: Guayama, PR
- Testing conducted during August 2015
- Project team: NREL, AES, PREPA, GP Tech
- Controls demonstrated:
  - AGC
  - Primary frequency response (PFR)
  - Fast frequency response (FFR)




- 20 MW Pecos Barilla PV plant
- Location: Stockton, TX
- Testing conducted during September 2015
- Project team: NREL, First Solar, ERCOT
- Controls demonstrated:
  - Ramp control
  - AGC
  - PFR
  - FFR
  - Voltage control
  - Reactive power control
  - Power factor control

Project report: [www.nrel.gov/docs/fy16osti/65368.pdf](http://www.nrel.gov/docs/fy16osti/65368.pdf)

# Plant AGC Performance

## AGC Test - August 14, 2015




# Snapshot of PREPA AGC Display #4

No conventional unit is selected for AGC, AES Ilumina is the only active unit

Unit Overview		Stream		Combined Cycles		Gas Turbines		Hydroelectric		BESS		Cogeneration		
AGC Control Status: Area Control Error: -3.1 MW		RESERVES: MW		CONTROLLED 85		SPINNING (F/S) 262 / 262		OPERATING 957		FREQUENCY GENERATION 59.973 Hz 2817 MW		Emergency Assist		
SCADA ILEX		Desired Frequency: 60.000 Hz		Time Error: -0.3170 sec		Control State: limited		Temporary Generation: -5.0 MW		Control State: normal		Raise: 0.0 MW		
										Control State: boost		Lower: 0.0 MW		
										Control State: assist		Lower: 6.7 MW		
Unit	Pulse / SetPt	Generation Actual	Generation Desired	Maximum Capacity	Sustained High	Limits Low	Conn. Status	AGC	Remote Status	Remote Control	Base Point Source	Control Type	Operating Mode	Follow Mode
SAN JUAN 5 CC COMBINED SJS GAS SJS STM	0.0	200	199	220	198	2.0	■	○	LOCAL	LOCAL	OPERATOR BASE	INFLEXIBLE INDEPENDENT	TEST	○
SAN JUAN 6 CC INDEPENDENT SJS GAS SJS STM	0.0	0.0	100	0.0	0.0	0.0	□	○	LOCAL	LOCAL	OPERATOR BASE	INFLEXIBLE INDEPENDENT	OFF	○
SAN JUAN 7	0.0	87.4	90.0	100	90.0	70.0	■	○	REMOTE	LOCAL	ECONOMIC	FLEXIBLE INDEPENDENT	MANUAL DISPATCH	○
SAN JUAN 8	0.0	0.0	88.9	1.0	1.0	1.0	□	○	REMOTE	LOCAL	OPERATOR BASE	INFLEXIBLE INDEPENDENT	OFF	○
SAN JUAN 9	0.0	83.8	86.3	100	90.0	70.0	■	○	REMOTE	LOCAL	OPERATOR BASE	INFLEXIBLE INDEPENDENT	MANUAL DISPATCH	○
SAN JUAN 10	0.0	0.0	70.0	1.0	1.0	1.0	□	○	REMOTE	LOCAL	OPERATOR BASE	INFLEXIBLE INDEPENDENT	OFF	○
PALO SECO 1	0.0	51.6	72.8	53.0	53.0	30.0	■	○	LOCAL	LOCAL	OPERATOR BASE	INFLEXIBLE INDEPENDENT	MANUAL DISPATCH	○
PALO SECO 2	0.0	72.0	50.6	85.0	1.0	1.0	■	○	LOCAL	LOCAL	OPERATOR BASE	INFLEXIBLE INDEPENDENT	MANUAL DISPATCH	○
PALO SECO 3	0.0	0.0	185	1.0	1.0	1.0	□	○	LOCAL	LOCAL	OPERATOR BASE	INFLEXIBLE INDEPENDENT	OFF	○
PALO SECO 4	0.0	0.0	180	1.0	1.0	1.0	□	○	LOCAL	LOCAL	ECONOMIC	FLEXIBLE INDEPENDENT	OFF	○
COSTA SUR 3	0.0	0.0	64.9	85.0	1.0	1.0	□	○	LOCAL	LOCAL	OPERATOR BASE	INFLEXIBLE INDEPENDENT	OFF	○
COSTA SUR 4	0.0	0.0	72.5	1.0	1.0	1.0	□	○	LOCAL	LOCAL	OPERATOR BASE	INFLEXIBLE INDEPENDENT	OFF	○
COSTA SUR 5	0.0	384	350	390	350	300	■	○	LOCAL	LOCAL	ECONOMIC	FLEXIBLE INDEPENDENT	MANUAL DISPATCH	○
COSTA SUR 6	0.0	377	337	380	380	300	■	○	LOCAL	LOCAL	ECONOMIC	FLEXIBLE INDEPENDENT	MANUAL DISPATCH	○
AGUIRRE 1	0.0	231	361	243	243	230	■	○	LOCAL	LOCAL	ECONOMIC	FLEXIBLE INDEPENDENT	MANUAL DISPATCH	○
AGUIRRE 2	0.0	389	389	450	390	390	■	○	REMOTE	REMOTE	ECONOMIC	FLEXIBLE INDEPENDENT	ECONOMIC REGULATING	○
ECO PP 416	0.0	436	433	530	480	300	■	○	REMOTE	REMOTE	ECONOMIC	FLEXIBLE INDEPENDENT	ECONOMIC REGULATING	○
AES PP 285	0.0	330	511	325	325	161	■	○	LOCAL	LOCAL	OPERATOR BASE	FLEXIBLE INDEPENDENT	MANUAL DISPATCH	○


# CAISO Resource Breakdown – April 24, 2016

Generation Breakdown --- 04/24/2016




Source: CAISO


# Testing 300 MW PV Plant





# PV Participation in CAISO AGC



$$ACE = -\Delta P_{tie} - 10B(f_a - f_s) + I_{ME} + I_T$$




# AGC Participation Tests







- 4-sec AGC signal provided to PPC
- 30 MW headroom
- Tests were conducted at three resource intensity conditions (30 minutes at each condition):
  - Sunrise
  - Middle of the day
  - Sunset
- 1-sec data collected by plant PPC

# Example of AGC Test Live Data





# AGC Participation Tests - continued



# AGC Participation Tests- Summary


## Measured Regulation Accuracy by 300 MW PV Plant

Time Frame	Solar PV Plant Test Results
Sunrise	93.7%
Middle of the day	87.1%
Sunset	87.4%


## Typical Regulation-Up Accuracy of CAISO Conventional Generation

	Combined Cycle	Gas Turbine	Hydro	Limited Energy Battery Resource	Pump Storage Turbine	Steam Turbine
Regulation-Up Accuracy	46.88%	63.08%	46.67%	61.35%	45.31%	40%

# Active Power Curtailment Test




# Frequency Droop Tests




$$\text{Droop} = \frac{\Delta f / 60\text{Hz}}{\Delta P / P_{rated}}$$

- 3% and 5% under and over-frequency tests
- 20% headroom
- $\pm 36$  mHz dead band
- Actual frequency event time series measured in the U.S. Western Interconnection



## Example of 3% droop test (under-frequency)



## Measured droop response




# Measured Reactive Power Capability and Voltages at POI



- Reactive power tests at high and low power production levels
- The plant meets the proposed CAISO reactive power requirements

# Conclusions

- Modern wind and solar PV power plants:
  - Not just a source of variable energy
  - They can provide all types of reliability services like conventional power plants
- Active and reactive power controls can leverage RE generation's value from being a simple variable energy resource to a resource that provides a wide range of ancillary services.
- New markets incentivizing the participation of renewables in ancillary service markets are evolving in US (CAISO, PJM, ERCOT, Hawaii) and worldwide
- 175 GW Roadmap: Recommended for TNEB to start considering grid services by RE



Thank you!

[www.nrel.gov](http://www.nrel.gov)

